

No. Fail: JBPM/IP/BKK:700-7/2/7-19 (21)
(PEMBAHARUAN: KESEMBILAN BELAS)

SIJIL PEPASANGAN KESELAMATAN KEBAKARAN

APPROVAL CERTIFICATE

Jabatan Bomba dan Penyelamat Malaysia
dengan ini memperakukan
Fire and Rescue Department of Malaysia
hereby certify



CERTIFIED TO
ISO 9001 : 2008
CERT. NO: AR 5037



CERTIFIED TO
ISO9001 : 2008
CERT. NO: AR5037

BAHAN KELAS 'O'

Berdasarkan Piawaian
Complying with

BS 476: PART 6: 1989 & BS 476: PART 7: 1997

Syarikat Berdaftar
Registered company

INSULFLEX CORPORATION SDN BHD (743287-M)
Lot 6 & 8, Jalan P/1,
Kawasan Perindustrian Bangi,
46350 Bandar Baru Bangi,
Selangor Darul Ehsan.

Tempoh sah perakuan: **31/08/2015 hingga 30/08/2016**

(PKPjB HARON BIN HJ TAHIR)

Bahagian Keselamatan Kebakaran,
b.p. Ketua Pengarah
Jabatan Bomba dan Penyelamat Malaysia.

Tarikh: **14** September 2015

**** Peringatan:**

Sila patuhi sepenuhnya syarat-syarat dan had kegunaan
seperti dalam Lampiran A1

No. Fail: **JBPM/IP/BKK:700-7/2/7-19(21)**
No.Siri: **BB/bla/304/97 (P19)**

LAMPIRAN A1

Jenis Bahan Binaan	: INSULFLEX-CLOSED CELL NITRILLE RUBBER MATERIAL
Model & Spesifikasi	: TEBAL 21mm & DENSITY 120kg/m²
Nama & Alamat Pengeluar	: INSULFLEX CORPORATION SDN BHD
No. Laporan ujian/Tarikh	: WARRES No.60995 – 14/10/94, SIRIM 2000FE1417 (16/08/2008), 2005FE0044 (22/02/2005), 2005FE0045 (22/02/2005), 2006FE0163 (28/06/2006), 2006FE0134 (09/06/2006), 2011FE0139 (06/06/2011) & 2011FE0124 (10/05/2011)
Skim Persijilan Barangan	: SIRIM QAS INT NO. LI009301, NO SIRI 018737 (SAH SEHINGGA 30/08/2016)
Had Kegunaan	: PENGGUNAAN SEBAGAI BAHAN PENEBAT PADA SISTEM 'DUCT' HENDAKLAH MEMATUHI SPESIFIKASI UJIAN DAN UBBL 1984 SERTA PERLU MEMATUHI SYARAT-SYARAT TAMBAHAN SEPERTI DI LAMPIRAN A2 & A3.



Tempoh sah perakuan: **31/08/2015 hingga 30/08/2016**